Scott. II-29—27,004—25-11-25.

P W & L (1926) Department.

Mus. SERIES.

G.O. No. 1044-W

DATED 17-8-26.

[Despatch Abstract.]

C.F. 32 (a)

In reply, please quote number, date and short title *

PUBLIC WORKS DEPARTMENT

Received ..... Registered .....



From (Name) W. G. MCLESWERTH, Esq.,
Offg. Chief Engineer, P.W.D.
(Designation) General, Buildings and Roads.

Post Box 410., (Station) Chepauk, M a d r a s.

Telegraphic Address C. E.

To The Secretary to Government,
Public Works & Labour Department,
M A D R A S.

No. 1783 Wks / 26-2., *dated* 15th July 1926

Sir,

Enclosures for Irrigation and Works & Law (Secl.) Dept. Ltr. Coo 3678 C/26

Spare Copies .....

IMPROVEMENTS TO ALIPURAM JAIL, BELLARY. REF:- G.O.NO.1509 W., DATED 24TH SEPTEMBER 1925 AND PARA 3 OF G.O.NO.100-W, DATED 21ST JANUARY 1926.

****

I forward herewith for the sanction of Government plans and estimate amounting to Rs.1,37,000 for certain improvements to Alipuram Jail, Bellary. A copy of my note on the case is also enclosed.

1/p: 3-4

enclosed.

2. The Inspector-General of Prisons has requested that steps may be taken for the early execution of the work. There is a grant of Rs.70,000/- for the work in the current year's budget (P.) of E.W.Budget (E)

S Ramanayalu 16/7/26

for Chief Engineer, P.W.D.

16.7.26

Documents Accompanying.

(1) One estimate.
(2) Plans B No.23 of 26; B No.24 of 26; B No. 25 of 26; one sketch and 3 plans B 604; B 604 A and B No.604 B of 25.
(3) Note by the Chief Engineer, P.W.D.No.1783 Wks/26-1, dated 15th June 1926.

Note by the Chief Engineer, P.W.D., No. 178306/26-1 d/ 15th July 26.

****

In G.O.No.1509 W, dated 24th September 1925, certain improvements to the Alipuram Jail, Bellary, at an approximate cost of Rs.86,000 were approved.

2. The Superintending Engineer, Madras Circle, now submits for sanction detail plans and estimates amounting to Rs.1,28,500 for the work.

The particulars of the plans and the estimate are as follows:-

Description	Amount of detail estimate.	Amount of approximate estimate
	Rs-	Rs.
Two Hospital blocks Nos.10 & 11 of Site plan B.No.23/1926 and B.Nos.24 & 25/1926 (a) Providing iron gratings between masonry pillars (b) Fixing galvanised corrugated iron sheets to the underside of the verandah roof	26,700	32,000
Replacing wooden doors and windows by iron doors and fixed grills in blocks 1 to 9 22 to 26 and 28 of the site plan as per plans B.Nos.604, 604 A, 604 B/1925 with a sketch of 1925 for an iron grated door by the Superintendent, Public Works Workshops, Madras	1,00,030	54,000
Trainage and cartage of materials L.S.	3,760	
Cartage of doors and windows from the Jail to P.W.D.Stores	110	
	1,30,600	
Deduct value of door and window frames likely to be realized in auction	2,100	
Total ... Rs.	1,28,500	86,000

3. The plans and the estimate have been scrutinised in the Chief Engineer's office and it is observed that the excess of Rs.42,500 over the approximate estimate based on lump sum rates, is chiefly due to:--

(a) the provision for filling in the semi circular arched openings over doors and windows with brick masonry over new cutstone lintels

(b)

(b) the provision for rebuilding the sides of proposed doors and windows as well as verandah pillars with burnt stone in cement, and

(c) the enhanced rates for iron doors and gratings ~~of~~ based on quotations furnished by the General Superintedent Public Works Workshops, Madras.

4. Cutstone lintels are proposed to be introduced below the skewbacks of arches. This is undesirable. The semi circular heads of doors should be provided with iron bars.

5. The type of door shown in the Public Works Workshops sketch has no angle iron stop at the bottom free ~~e~~end and is therefore unsafe in an association ward.

The Superintending Engineer should arrange to provide suitable doors and gratings in consultation with the Jail Department whose countersignature should be obtained in the plans and estimates.

6. The method of fixing the corrugated iron sheets below verandah rafters with 12" bolts and nuts, is not shown.

7. With these remarks, the plans and estimate as altered in the Chief Engineer's office, amounting to Rs.1,37,000 are recommended for sanction.

12/7.

Offg.Chief Engineer, P.W.D.
General, Buildings & Roads

Copy of letter No. 1783 Wks./26-2, dated 15th July 1926, from the Offg. Chief Engineer, (General, Roads and Buildings.)

Subject:- Improvements to Alipuram Jail, Bellary.

Ref:- G.O.No. 1509-W., dated 24th September 1925 and paragraph 3 of G.O.No.100-W., dated the 21st January 1926.

I forward herewith for the sanction of Government plans and estimate amounting to Rs. 1,37,000 for certain improvements to Alipuram Jail, Bellary. A copy of my note on the case is enclosed.

2. The Inspector-General of Prisons has requested that steps may be taken for the early execution of the work. There is a grant of Rs. 70,000/- for the work in the current year's budget.

6 / 1 / PWD

Improvements to Alpuram Jail.
Bellary. Detailed plans & estimate

Cpo 7798/26 pp1 ref

From the CE (R&B) no 1783 WB/26.2 dy 15.7.26

Put up for a file on Gen Cpo

The approximate estimate approved in Govt + 1509 W dy 24.9.25 for the above work amounted to Rs 86,000

Detailed estimate now recommended by the CE (R&B) amounts to Rs. 1,37,000

Excess Rs 51,000

The reasons for this excess are stated in paras 3 to 6 of the CE's note on pp 3.4 of.

C.W. budget

There is a provision of Rs 70,000 for the work in the current year's budget and the D.G of Prisons has recently requested ~~in another file~~ that the work maybe completed as quickly as possible. A draft order is submitted and it may be sent to Law (Govt) & Finance for acceptance

23.7.26 25.7.26

26.7.26

Secy

26/7

Law
Finance

Law Officer Dept

U.S.

pp.

The draft order may be accepted and the file passed on to Govt Finance

28.7.26 28/7

V.K. 31.7

30/7 Finance

2/

Finance (Exp.)

The variations between the approximate estimate sanctioned in September 1925 and the detailed estimates now under consideration is large as shown below:—

(1) Approximate estimate	= Rs. 86,000.	para 1 on page 3 C.F.
(2) Detailed estimate submitted by the C.E.	= 1,37,000	para. 7 on page 4 C.F.
(3) Excess over the approximate estimate [Item (2) – item (1) above]	= 51000.	

The percentage of increase is about 60.

The reasons for the increase are explained in para 3 of C.E's note on pp: 3-4 C.F.

2. Submitted that the draft order may be

There is a provision of Rs 70,000 for this current year's budget under "41 Civil works" p: 7 of C.W. budget

9.8.26

9.8.26

PWD

Fin: N.O. 22 S/11 Exp-1.

PW & L Dept.

8933C
10 AUG 1926
EXECUTIVE ENGINEERS OFFICE
PUBLIC WORKS DEPARTMENT

In reply to Finance or Legl Dept. please quote the number and date of this letter.

10.8.26

10.8.26

Secy

Secy 11/8

Civil 14.8
Revs 16-8

Secy 16/8

Secy 16/8

Sectt. II-5 (b)—25,000—25-11-25. (6)

P. W. DEPARTMENT.

	Date.	Initials.
When received for Fair-copying.		
When copied ..		
When examined ..	17/8/26	
When signed ..		
When despatched ..		

Buildings - Jails - Bellary - Improvements to Alipuram jail - detailed plans and estimate - Rs 1,37,000 - Approved -

READ AGAIN G.O. No. 1509W, dated 24.9.1925.

" " " " " 192 .

READ ALSO:-

C. No. ..... From the C.E. (R&B), No. 17834/Mis. No. 2 dated 15.7.1926.

" " ..... " " Note of the CE (R&B) " 17834/Mis/No. 1 " 8/15.7.1926.

" " ..... " " ..... " ..... " 192 .

ORDER.

No. 1044W, dated 17-8-1926.

The detailed plans and estimates as altered in the CE's ltr amounting to Rs 1,37,000 for improvements to Alipuram Jail, Bellary, subject to the remarks of the CE (R&B) is approved in supersession of the approximate estimate of Rs 86,000 approved in GO No 1509W dy 24.9.1925.

2. The CE (R&B) is requested to arrange & obtain the Countersignature of the I.G. Prisons to the detailed plans and estimate and to commence the work as early as possible.

DESPATCHED
17 AUG 1926

The CE (R&B) with plans Bs Nos 23, 24, 25 of 1926, one sketch & 3 plans B 604, B 604A, B 604B & 25 and estimate in Law (Edn) and (Edn) Depts.